



# Certificate of Compliance

**Certificate:** 2061370

**Master Contract:** 238720

**Project:** 2524038

**Date Issued:** June 18, 2012

**Issued to:** Pushna International Inc.  
6222 Richmond Ave.  
Suite 783  
Houston, TX 77057  
USA  
Attention: Sunil Karamchandani

*The products listed below are eligible to bear the CSA Mark shown*



*Dorel Stefan*

**Issued by:** Dorel Stefan

## PRODUCTS

**CLASS 4418 02** - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

**Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III**

Explosion-Proof Housings 1010PAEa-b, 1010PWEa-b, 1014PSEa-b, and 1016PSEa-b; Type 4X and IP68 (1m,1hr); Ambient temperature range -50°C to +125°C (model 1010PWEa rated for -50°C to +80°C)

a=Label shape & Listed certification bodies: blank, H, M

b=Threaded entries: 01, 02, 03, 10





**Certificate:** 2061370

**Master Contract:** 238720

**Project:** 2524038

**Date Issued:** June 18, 2012

### **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 25-1966 (R2004)	Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CSA C22.2 No. 30-M1986 (R2003)	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CSA C22.2 No. 94-M91 (R2006)	Special Purpose Enclosures
CSA C22.2 No. 60529:05	Degrees of Protection Provided Enclosure (IP Code)

### **MARKINGS**

All markings shall be in accordance with the requirements of the local regulatory authorities and related standards.

The manufacturer's etched stainless steel nameplates are permanently secured with stainless steel rivets onto the surface of the housing cover. Depending on which style housing cover is used, the nameplates can be full-moon or half-moon shape.

- Manufacturer's name: "PUSHNA", or CSA Master Contract Number "238720", adjacent to the CSA Mark in lieu of manufacturers name.
- Model number: As specified in the PRODUCTS section, above.
- Ambient temperature rating: As specified in the PRODUCTS section, above.
- Manufacturing date in MMY format, or serial number, traceable to month of manufacture.
- Enclosure ratings: As specified in the PRODUCTS section, above.
- The CSA Mark, as shown on the Certificate of Compliance.
- Hazardous Location designation: As specified in the PRODUCTS section, above (may be abbreviated).
- Cautions on use in hazardous locations "OPEN CIRCUIT BEFORE REMOVING COVER and OUVRIRE LE CIRCUIT AVANT D'ENLEVER LE COUVERCLE".

Note: The manufacturers name and the cautionary statement are embossed on the cover.

*Note - Jurisdictions in Canada may require these markings to also be provided in French language. It is the responsibility of the manufacturer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities. It is the responsibility of the manufacturer to determine this requirement and have bilingual wording added to the "Markings".*



## Supplement to Certificate of Compliance

Certificate: 2061370

Master Contract: 238720

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

---

Project	Date	Description
2524038	June 18, 2012	Update to report 2061370 to include new drawings for an alternate Housing and nameplates for series 1010, 1014 and 1016. Update Housings ingress rating from IP66 to IP68 using FM Test Report.
2158615	May 28, 2009	Update to report 2061370 to change drawings 1010-E-A and 1016-E-A dates from 05/22/2008 to 06/20/2008. They had the incorrect dates in the original report and no drawings were changed under this project.
2061370	September 12, 2008	Original Certification - Explosion-Proof Housings 1010PAE-a, 1010PWE-a, 1014PSE-a, and 1016PSE-a; Class I, Division 1, Groups BCD; Class II, Div. 1, Grps EFG; Class III, Type 4X, IP66.