



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

### **1010PAEa-b Housing.**

XP/I/1/BCD/Ta = -50°C to +125°C; Type 4X, IP68  
DIP/II,III/1/EFG/Ta = -50°C to +125°C; Type 4X, IP68  
a = Certifications H, M or BLANK.  
b = Threaded entries 01, 02, 03 or 10.

### **1010PWEa-b Housing.**

XP/I/1/BCD/Ta = -50°C to +80°C; Type 4X, IP68  
DIP/II,III/1/EFG/Ta = -50°C to +80°C; Type 4X, IP68  
a = Certifications H, M or BLANK.  
b = Threaded entries 01, 02, 03 or 10.

### **101aPSEb-c Housing.**

XP/I/1/BCD/Ta = -50°C to +125°C; Type 4X, IP68  
DIP/II,III/1/EFG/Ta = -50°C to +125°C; Type 4X, IP68  
a = Material grade 4 or 6.  
b = Certifications H, M or BLANK.  
c = Threaded entries 01, 02, 03 or 10.

### Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D and Dust Ignitionproof for Class II, Division 1, Groups E, F and G, Class III, hazardous locations, indoors and outdoors (Type 4X and IP68).

### FM Approved for:

Pushna International Inc.  
Houston, Texas, USA

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

|                 |      |
|-----------------|------|
| C22.2 No. 0.4   | 2009 |
| C22.2 No. 0.5   | 2008 |
| C22.2 No. 25    | 2009 |
| C22.2 No. 30    | 2007 |
| C22.2 No. 94    | 2011 |
| C22.2 No. 60529 | 2010 |

Original Project ID: 3031933C

Approval Granted: June 23, 2008

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date           | Report Number | Date |
|---------------|----------------|---------------|------|
| 3044782       | March 26, 2012 |               |      |

FM Approvals LLC



J.E. Marquedant  
Group Manager, Electrical

26 March 2012  
Date